

Confirmation

LEED v4 and LEED (2009)

Steelmaster 1200WF

supplied by
Jotun A/S

SP Technical Research Institute of Sweden received from Jotun A/S a product sample which is representative of the manufactured product. It has been tested in accordance with relevant test method (CDPH method ver 1.1 2010, see test report no. 5P01717-10)

The test results of the tested product prove that the product qualifies for LEED 2009 and LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health) and a TVOC of $\leq 0.5 \text{ mg/m}^3$ in both office and class room

SP Technical Research Institute of Sweden
SP Chemistry, Materials and Surfaces - Chemistry



Ulrika Johansson

SP Technical Research Institute of Sweden

Postal address

SP
Box 857
SE-501 15 BORÅS
Sweden

Office location

Västeråsen
Brinellgatan 4
SE-504 62 BORÅS

Telephone / Telefax

+46 10 516 50 00
+46 33 13 55 02

E-mail / Internet

info@sp.se
www.sp.se

Bank account

6662-275 695 611

Reg.number

556464-6874

Svenska Handelsbanken

SWIFT: HAND SE SS

IBAN: se156000000000275695611

VAT number

SE556464687401